



NOTES:

1. All piping configurations of the Backflow Assembly shall be done with Galvanized pipe.
2. BACKFLOW PREVENTION DEVICE (R.P.Z.) designated by City of Kerrville Standard Product List.
3. This installation approved for temporary line loading only.
4. RPZ must be tested according to most recently adopted City of Kerrville plumbing code.

Backflow Prevention For Water Main Loading

City of Kerrville
Standard Specifications

| | | | |
|-------|----------|---------------|-----|
| SIZE | FSCM NO. | DWG NO. | REV |
| SCALE | | | |
| | | 380.12 | |
| | | SHEET | |